



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx CML 18.0174 Issue No: 0 Certificate history:  
Issue No. 0 (2019-03-27)

Status: **Current** Page 1 of 3

Date of Issue: **2019-03-27**

Applicant: **CMP Products Ltd**  
Unit 36 Nelson Way, Nelson Park East, Cramlington, NE23 1WH  
**United Kingdom**

Equipment: **A2e100, RA2e100, A2e100HCX, RA2e100HC, A2e100/M, RA2e100/M, A2e100HC/M, Ra2e100HC/M Series Cable Glands**

*Optional accessory:*

Type of Protection: **Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"**

Marking:  
Ex eb I Mb  
Ex eb IIC Gb\*  
Ex nR IIC Gc\*  
Ex ta IIIC Da\*  
IP66 IP67 IP68 (30m for 12 hours)  
Ts: -60°C to +130°C  
\* Not A2e100/M, RA2e100/M, A2e100HC/M, RA2e100HC/M Series

Approved for issue on behalf of the IECEx  
Certification Body:

R C Marshall

Position:

Certification Officer

Signature:  
(for printed version)

Date:

2019-03-27

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**Certification Management Limited**  
Unit 1, Newport Business Park  
New Port Road  
Ellesmere Port, CH65 4LZ  
United Kingdom





# IECEX Certificate of Conformity

Certificate No: IECEX CML 18.0174

Issue No: 0

Date of Issue: **2019-03-27**

Page 2 of 3

Manufacturer:

**CMP Products Ltd**

Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH  
**United Kingdom**

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2017</b> Edition:7.0	Explosive atmospheres - Part 0: Equipment - General requirements
<b>IEC 60079-15 : 2017</b> Edition:5.0	Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
<b>IEC 60079-31 : 2013</b> Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
<b>IEC 60079-7 : 2015</b> Edition:5.0	Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:

[GB/CML/ExTR18.0295/00](#)

Quality Assessment Report:

[GB/CML/QAR19.0001/00](#)



# IECEX Certificate of Conformity

Certificate No: IECEx CML 18.0174

Issue No: 0

Date of Issue: 2019-03-27

Page 3 of 3

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

The A2e100, RA2e100, A2e100HCX, RA2e100HC, A2e100/M, RA2e100/M, A2e100HC/M, Ra2e100HC/M Series Cable Glands allow circular unarmoured or braided/screened cables to enter associated enclosures to which they are fitted (as defined by their coding) without compromising the explosion protection that it provides.

Refer to Annex for full description and conditions of manufacture.

**SPECIFIC CONDITIONS OF USE: NO**

### Annex:

[IECEX CML 18.0174 Iss. 0 Certificate Annex.pdf](#)

**Annexe to:** IECEx CML 18.0174 Iss. 0  
**Applicant:** CMP Products Ltd  
**Apparatus:** A2e100, RA2e100, A2e100HCX,  
RA2e100HC, A2e100/M, RA2e100/M,  
A2e100HC/M, Ra2e100HC/M Series  
Cable Glands



## Product Description

The A2e100, RA2e100, A2e100HCX, RA2e100HC, A2e100/M, RA2e100/M, A2e100HC/M, Ra2e100HC/M Series Cable Glands allow circular unarmoured or braided/screened cables to enter associated enclosures to which they are fitted (as defined by their coding) without compromising the explosion protection that it provides. They are manufactured from the following component parts:

- Metallic entry item hexagonal in form which is partially threaded at one end with a male metric or NPT thread used to secure the entry item to the associated enclosure. At the other end there is a partially turned external surface which is provided for placement of the product markings. At this end the internal profiled bore of the component is partially threaded with a female thread to accept engagement of the outer seal nut.
- Elastomeric sealing ring which is inserted into the female threaded end of the entry item which, when displaced by tightening of the outer seal nut, secures the incoming cable in place, along with providing 'sealing' and ingress protection.
- Metallic stepped skid washer hollow 'top hat' in form, is fitted into the recessed bore of the outer seal nut. Which upon tightening of the outer seal nut, aids axial displacement of the sealing ring and limits any twisting of the cable within the cable gland during installation.
- Metallic outer seal nut, hexagonal in form, is partially threaded at one end with a male thread which engages with the entry items and upon tightening displaces the sealing ring onto the cable. Internally the bore is recessed at one end to accommodate the stepped skid washer, and the other end is machined with an internal radius to reduce the risk of damage to cable sheath/jacket.
- Model code series suffixed 'HC' for all cable gland model series, up to either gland size 75S or gland size 75 (dependent upon model series), which includes an alternative nut that is extended to provide a plain circular portion, to facilitate the connection of a hose that provides additional mechanical and environmental protection of the cable terminated within the cable gland. The compression nut may alternatively be machined with a dimensionally equivalent 'smaller' certified gland size hose connection feature. In this instance the upper cable sealing diameter range being reduced accordingly.

The cable gland and sealing ring sizes are determined by the entry thread and cable range take sizes:

Gland Size	Entry Thread			Cable Outer Sheath	
	Standard (Metric)	Standard (NPT)	Optional (NPT)	Min. (mm)	Max. (mm)
16	M16x1.5	3/8"	-	3.2	8.0
20S16	M20x1.5	1/2"	3/4"	3.2	8.0
20S	M20x1.5	1/2"	3/4"	6.5	11.2
20	M20x1.5	1/2"	3/4"	7.0	13.5

Unit 1, Newport Business Park  
New Port Road  
Ellesmere Port  
CH65 4LZ

T +44 (0) 151 559 1160  
E info@cmllex.com

[www.cmllex.com](http://www.cmllex.com)

Company Reg No. 8554022 VAT No. GB163023642





Gland Size	Entry Thread			Cable Outer Sheath	
	Standard (Metric)	Standard (NPT)	Optional (NPT)	Min. (mm)	Max. (mm)
20L	M20x1.5	1/2"	3/4"	8.7	14
25	M25x1.5	3/4"	1"	11.5	19.5
25L	M25 x 1.5	3/4"	1"	14.0	20.0
32	M32 x 1.5	1"	1 1/4"	19.0	25.5
32L	M32 x 1.5	1"	1 1/4"	20.2	26.3
40	M40 x 1.5	1 1/4"	1 1/2"	25.0	32.2
50S	M50 x 1.5	1 1/2"	2"	31.0	38.2
50	M50 x 1.5	2"	2 1/2"	35.6	44.0
63S	M63 x 1.5	2"	2 1/2"	41.5	49.9
63	M63 x 1.5	2 1/2"	3"	48.2	54.9
75S	M75 x 1.5	2 1/2"	3"	54.0	61.9
75	M75 x 1.5	3"	3 1/2"	61.1	67.9
90	M90 x 2.0	3 1/2"	4"	66.6	79.9
100	M100 x 2.0	3 1/2"	4"	76.0	89.0
115	M115 x 2.0	4"	5"	86.0	97.9
130	M130 x 2.0	5"	-	97.0	114.9

### Design Options

The front threaded entry item may be manufactured with a profiled groove to captivate an 'O' ring seal which locates on the mating face of the associated enclosure. This option having the cable gland type designation prefixed with the letter R, e.g. RA2e100 Series.

The front threaded entry item may be manufactured with any larger metric or NPT thread form size from the sizes certified.

The front threaded entry item may be manufactured with an alternative nearest equivalent recognised thread type and size to the metric thread sizes certified.

Metric threaded cable entry spigots of all cable gland model series to be manufactured with a thread pitch between 0.7mm and 2.0mm, with 1.5mm as standard.

The optional use of an internally fitted brass or brass plated ingress disc between the seal and the stepped washer component parts within 'A2e100' Series & 'RA2e100' Series cable glands.

The following low profile 'across corners' envelope cable gland sizes, with the cable gland size suffix code designation 'P':

Gland Size	16P	20S16P	20SP	20P	20LP	25P*	25LP*
------------	-----	--------	------	-----	------	------	-------

(\* not available in aluminium)



The differences to the standard cable gland sizes, are-

- The entry item component is machined from round bar, equal to the standard gland size across corners dimensions, with a central portion machined to a hexagonal profile, having reduced across flats from the standard gland size. Along with a minor increase in length resulting from an increase to the conical wall thickness.
- The gland nut component (dependent upon model series and gland size), having reduced across flats and across corners dimensions from the standard gland size. Along with their maximum inner most bore dimension being reduced

**Materials of manufacture:**

The standard material supplied is:

Brass	BS EN 12164:2011/ BS EN 12168:2011 Grade CuZn39Pb3 (CW614N) All brass manufactured component parts can be optionally nickel plated to a maximum of 0.008mm
-------	---

Alternate materials are:

Stainless steel	BS EN 10088-3:2014 Grades 316S11, 316S13, 316S31, 316S33, 316L
Mild steel	BS EN 10277-2:2008 Grades 220M07, 230M07 (EN1A) / 220M07Pb, 230M07Pb (EN1APb)
Aluminium	BS EN 573-3:2013 / BS EN 755-1-3:2008 Grade 6082 T6, 6262 T6 / BS EN 1676:2010 Grade LM25 TF Aluminium will contain less than 6% magnesium

**Alternative entry component thread forms:**

Metric	ISO 965-1, ISO 965-3 medium fit (6g) for external threads
ET (Conduit)	BS31:1940 (1979), Table A
PG	DIN 40430:1971
BSPP	BS2779:1986 class A full form for external threads
BSPT	BS21:1985 standard threads only as clause 5.4, gauging to clause 5.2 system A
ISO	ISO 7/1:1994, gauging to ISO 7/2 clause 6.3 for external threads
NPT	ANSI/ASME B1.20.1-2013 gauging to clause 3.2 for external threads
NPSM	ANSI/ASME B1.20.1-2013 gauging to clause 6.4 for external threads

**Notes:**

- Sira 16ATEX3165 and IECEx SIR 16.0053 are superseded by this certificate.
- The product covered by Issue 0 of this certificate remains identical to that previously covered by Sira 16ATEX3165 and IECEx SIR 16.0053.
- Where Sira 16ATEX3165 and IECEx SIR 16.0053 are specified in other product certification, or other technical specifications, this certificate reference for the product shall be used in its place; updating of the other product certificate or technical specification is not required.



## Conditions of Manufacture

The following are conditions of manufacture:

- i. Where the product incorporates certified parts or safety critical components the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.
- ii. The front threaded entry item may be provided with, but not limited to, an alternative nearest equivalent recognised thread type and size to the metric thread, whilst maintaining a tolerance of fit, equal or better than, a medium fit to ISO 965-1 & ISO 965-3.  
For example:
  - ET - BS 31:1940 (1979) Table 'A'
  - PG - DIN 40430:1971
  - BSPP - BS2279:1986 class A full form for external threads
  - BSPT - BS21:1985 standard threads only as clause 5.4, gauging to clause 5.2, system A.
  - ISO - ISO 7/1:1994 gauging to ISO 7/2 clause 6.3 for external threads.
  - NPSM - ANSI/ASME B1.20.1:1983 B1.20.1-1983 gauging to clause 9 for external threads.
- iii. Cable gland metallic parts are to be supplied in alike materials, alternatively a brass or nickel plated brass stepped skid washer may be used within steel and stainless-steel glands.
- iv. The front threaded entry item of any model series, when manufactured with a larger thread size to the standard metric or NPT sizes approved and detailed on the certification documentation will only differ as follows:
  - These entry item dimensions must remain the same:
    - The front bore diameter and profile and sealing ring taper angle.
    - Outer seal engagement thread diameter and length.
  - All other dimensions may be altered to match those of the larger approved cable gland size, provided that the overall cable gland protrusion length (whichever is greater between the original cable gland size or the larger approved cable gland size) is not exceeded.
- v. Cable gland model code series suffixed 'HC' manufacturer with a 3/8" NPT threaded spigot shall not be marked suitable for Group I applications.
- vi. Cable gland sizes 25P and 25LP shall not be manufactured in aluminium.
- vii. Aluminium cable glands shall not be marked suitable for Group I applications.
- viii. Cable Glands supplied with ingress discs shall not be marked suitable for Group I applications.
- ix. Cable Glands supplied with ingress discs shall not be marked suitable for IPX7 or IPX8 applications.



## Specific Conditions of Use

None.